

KS22 V6 TRIO Gas Safestart Operating Procedure

1. Turn on kitchen ventilation system.
2. Enter Trio keycode and press tick.
3. AIR light will flash during ventilation check.
4. AIR light on.
5. GAS light flashes during gas test.
6. GAS light on.
7. Gas is now available.

In case of:

1. AIR light flashing and audible alarm sounding.

ACTION: Check ventilation is switched on.

2. GAS light flashing and audible alarm sounding.

ACTION: Check that all gas taps are turned off.

3. The KS22 V6 does not show any lights.

ACTION: Check EMERGENCY STOP push buttons.

To reset the TRIO KS22 V6 press STOP then enter the TRIO keycode and press tick. The system should run normally.

For further guidance call:

DO NOT TAKE RISKS. IF IN DOUBT ASK.

www.duomo.co.uk